

Test laboratory for the fire behavior of building materials, Dipl.-Ing. (FH) Andreas Hoch
Testing, supervising and certifying body, authorized by the building supervision authority

TEST REPORT

PB-Hoch-161296

for the proof of Fire behaviour according to DIN 4102, part 1
Translation of the German test report – no guarantee for translation of technical terms
external surveillance of the production by “SKZ” (II/2016)
SKZ no: 6282 & 6283 / Cert. no: SKZ A 7061

company	NICOLL POLSKA Sp. z.o.o. Ul. Energetyczna 6 56-400 Olesnica – Poland
production plant	NICOLL POLSKA Sp. z.o.o. Ul. Energetyczna 6 56-400 Olesnica – Poland
description of samples	waste water pipe, consisting of PP-HT
name of the material	„Tipplen H 880“ / „Tipplen K 850“
sampling	by “SKZ” in the production plant (external surveillance)
content of request	Proof of flammability to classify building materials to class B1 “schwerentflammbar” according to DIN 4102, part 1
date of visit in the production plant	13.10.2016
result	The examined product meets the requirements of class B1 for “schwerentflammbare” (hardly flammable) building materials according to DIN 4102, part 1 (May 1998). The product shows burning droplets.

This test report includes 3 pages and 2 enclosures.

Remark: If the above mentioned building material is not used as product according to MBO § 2, Abs. 9, Ziffer 1, there is no need for a general building supervisory test report.

This test report is not valid if the examined building material is used as product in the meaning of state building prescriptions (MBO § 17, Abs. 3).

This test report does not replace an eventually necessary proof of applicability concerning building supervisory or building laws in the meaning of state building prescriptions. This has to be verified by:

- “allgemeine bauaufsichtliche Zulassung” (general building inspectorate approval) or by
- „allgemeines bauaufsichtliches Prüfzeugnis” (general building inspectorate certificate) or by
- “Zustimmung im Einzelfall” (exceptional approval)

This test report can underlie building supervisory procedures

- for regular building products for the prescribed proofs of conformity
- for non regular building products for the needed proofs of applicability.

This test report must not be published and copied without preceding agreement of the test laboratory and if agreed, only during validity and unchanged concerning appearance and contents.